



ATTESTATION of conformity with European Directives

Product: **RCCB**
Reference: **EKL1-80 and EKL11-63**
Issued to: **ZHEJIANG ETEK ELECTRICAL TECHNOLOGY CO.,LTD**
Address: **NO.288 Wei 17th Road , Yueqing Economic Development Zone
Yueqing , Wenzhou , Zhejiang Province P.R.China**
Manufacturer: **ZHEJIANG CHANGAN ELECTRICAL ENGINEERING CO.,LTD.**
1P+N and 3P+N(neutral on right)
230/240V~(1P+N);400/415V~(3P+N); 50/60Hz
In=25A; 40A; 63A (EKL11-63); 25A; 40A; 63A; 80A (EKL1-80)
Inc=IΔc=6000A
Im=IΔm=500A for In:25A;40A ; 10In for In:63A;80A
IΔn=30mA; 100mA; 300mA
Grid distance = 50mm; Ui= 415V; Uimp=4kV
Material group=IIIa; Screw diameter=5,9mm

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
EN 61008-1:2012+A1:2014+A2:2014+A11:2015 +A12:2017 EN 61008-2-1:1994+A11:1998	B230093	07/09/2023

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), Oct 27th, 2023.

Charlie CHEN
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.